# PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC20190103012253O3

## NAME AND ADDRESS OF THE APPLICANT

Zhejiang Zhegui Electric Power Equipment Co., Ltd

Room 101, Building 1 and 2, Donggangjiayuan, Dongyangtian Village, Beibaixiang Town, Yueqing City, Wenzhou City, Zhejiang Province

## NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang Zhegui Electric Power Equipment Co., Ltd

Room 101, Building 1 and 2, Donggangjiayuan, Dongyangtian Village, Beibaixiang Town, Yueqing City, Wenzhou City, Zhejiang Province

## NAME AND ADDRESS OF THE FACTORY

Zhejiang Zhegui Electric Power Equipment Co., Ltd (V053459)

1/F,Building 1 , Donggangjiayuan, Dongyangtian Village, Beibaixiang Town, Yueqing City, Wenzhou City, Zhejiang Province

## PRODUCT NAME, MODEL AND SPECIFICATION

Low-voltage Switchgear Assemblies

JXF 主母线:InA=400A～10A,Icw=10kA;Ue=400V、380V,Ui=690V;50Hz;IP40、IP30

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 7251.12-2013

## TYPE OF CERTIFICATION SCHEMES

Type testing+Follow up factory inspection

**This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462176-2018 .**

**Valid from:** Aug.14,2020 **Valid until:** Sep.03,2024

**The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.**

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

**President:** _____

Lu Mei

CHINA QUALITY CERTIFICATION CENTRE 中国质量认证中心

# CHINA QUALITY CERTIFICATION CENTRE

Section 9,No.188,Nansihuan Xilu, Beijing 100070 P.R.China
http://www.cqc.com.cn

C 0343481